



Number	20BE0021/00	Replaces	--
Issue date	12-06-2020	Contract number	E 8090
Report number	180800005	Module	B (Type testing)
PIN	0063CU3005	Scope	Art. 4 of No. 813/2013 (2-8-2013) and/or 92/42/EEC (21-05-1992)

EC TYPE EXAMINATION CERTIFICATE (BED/R813)

Kiwa, notified body for council Directive 92/42/EC, hereby declares that the central heating boiler, type(s):

MicraCom Condens 24-AS/1 (H-PL)

Manufacturer **Saunier Duval**
Nantes, France

meet the requirements regarding useful efficiencies according to **article 4 of commission regulation (EU) No. 813/2013** and/or as described in the **Directive 92/42/EEC on efficiency requirements**.

Reference standard: EN 15502-1:2012+A1:2015 and EN 15502-2-1-2012+A1:2016

This certificate is only valid in combination with the appendix to this certificate, where specific information and/or conditions are given.

CERTIFICATE

Ron Scheepers
Kiwa



Number	20BE0021/00	Replaces	--
Issue date	12-06-2020	Page	1 of 1
Report number	180800005	Contract number	E 8090
PIN	0063CU3005	Scope	Art. 4 of No. 813/2013 (2-8-2013) and/or 92/42/EEC (21-05-1992)

APPENDIX TO EC TYPE EXAMINATION CERTIFICATE (BED/R813)

Saunier Duval

Specifications:

Model(s):

MicraCom Condens 24-AS/1 (H-PL)

Condensing boiler:	yes/∅
Range rated:	yes/∅
Low-temperature (**) boiler:	yes/∅
B1 boiler:	yes/no
Combination heater:	yes/∅

	Symbol	Value	Unit
Useful heat output			
At rated heat output and high-temperature regime (*)	P ₄	18,2	kW
At 30 % of rated heat output and low-temperature regime (**)	P ₁	6,1	kW
Useful efficiencies			
At rated heat output and high-temperature regime (*)	η ₄	87,6	%
At 30 % of rated heat output and low-temperature regime (**)	η ₁	96,6	%

(*) High-temperature regime means 60 °C return temperature at heater inlet and 80 °C feed temperature at heater outlet.

(**) Low temperature means for condensing boilers 30 °C, for low-temperature boilers 37 °C and for other heaters 50 °C return temperature (at heater inlet).

Calculated values are based on gross calorific value (reference conditions: 15 °C, 1013,25 mbar)